

# KRAAI WELL DRILLING, INC.

**Congratulations you are a proud owner of a new water well system!** We have completed the project and the system has been chlorinated for finalization. There are a few things left for you to do in order to complete this project properly. Your water must be sampled and then a well inspection must be done. You are testing for bacteria (coli form) and partial chemistry in your water. **THIS IS A VERY SENSITIVE TEST! PLEASE FOLLOW THESE DIRECTIONS CAREFULLY!**

- Run the water **continuously** for at least 48 hours through **at least two** outside faucets away from the sewage system.
- Water sample must be taken from the sample tap on the **tank!** Do not take samples from a faucet. This isolates the well and eliminates possible contamination from plumbing.
- Prior to pulling sample, run an additional 2-3 gallons of water from the sample tap on the tank. You will need a bucket or something for the water to run into.
- Clean the tap with rubbing alcohol or a disinfectant wipe. Let the water run momentarily to clean off any excess cleaners.
- **Do not touch the lid or rim of the sample bottles!** Fill the sample bottles to the shoulder of the bottle above the line.
- Refrigerate water samples until mailed or taken to the laboratory.
- **Water samples must be at the laboratory within 24 hours of sampling.** If mailing samples to the State of Michigan, send samples Monday thru Wednesday! We recommend driving samples to an onsite laboratory for better test results.
- Once you receive your test results, mail or fax water results to your local Health Department.
- Contact your local Health Department to have the well and pressure tank inspected.

**A water supply is approved after the health department conducts an inspection & receives the well log from the driller & a safe bacteria result from the homeowner.**

Please contact us at the number below with any questions.  
Thank you for using Kraai Well Drilling for your water servicing needs!

**KRAAI WELL DRILLING, INC.**

**110 124<sup>TH</sup> AVENUE**

**SHELBYVILLE, MI 49344**

**(269)-672-7188**

**(269)-672-5623-FAX**

**[www.kraaiwelldrilling.com](http://www.kraaiwelldrilling.com)**

**\*\*See reverse side for Laboratories and Health Departments\*\***

**\*\*ASK US ABOUT OUR WATER TREATMENT DIVISION\*\***